



Notes:

1. Grid (hinged locking type), or sealing plate if specified elsewhere in contract, to be in black coated grey iron.
2. Gully and grating to comply with BS65, BSEN 124 and BS 7903.
3. Concrete surround to be ST4. Where gully is adjacent to wall, infill with 50mm thickness of 3:1 sand/cement mortar.
4. Gully to be flush with footway surface where sealing plate is required or 5mm below footway surface for a grid installation.

All dimensions in mm



Drawing Title:

Standard Detail Footway Gully Combined Access / Inspection

Version	Amendment	Date
Checked By: B. Bartlett	Drawing Number: SD-500-06	Version: -
Date Issued: Oct 16		