



Notes:

1. Pipe to be built into Soakaway chamber with mortar designation (i)
2. Chamber diameter and depth and incoming pipe diameter and depth to be in accordance with the Contract Drawings and Appendices.
3. THIS CHAMBER MUST BE TREATED AS UNSUITABLE FOR PERSONNEL ENTRY.
4. PCC chamber rings are NOT to be provided with step irons etc.

Dimensions in millimetres unless stated otherwise.

Chamber Diameter	Granular Backfill			
	150	300	450	600
1050	150	300	450	600
1200	150	300	450	600
1500	150	300	450	600

Included in standard item coverage



Drawing Title:

Standard Detail Soakaway

Version	Amendment	Date
Checked By: B. Bartlett	Drawing Number: SD-500-09	Version: -
Date Issued: Oct 16		