



Pipe size (mm)	Dim 'a'
150 - 300	1.5m
375 - 600	2m
675 - 900	2.5m

General Notes:.

1. Pipe outfall exit velocity should not exceed 1.2m/s
2. The headwall and wingwalls should not project beyond or above the line of the bank.
3. No part of the structure should cut into any flood embankment.
4. Indicative layout and dimensions.

All dimensions in mm



Drawing Title:

Standard Detail

Headwall Structure to Comply with Environment Agency Consent to Discharge

Version	Amendment	Date
Checked By: B. Bartlett	Drawing Number: SD-500-17	Version: -
Date Issued: Oct 16		