


Notes:

1. All dimensions in mm.
2. Concrete grade ST1 to comply with Specification Clause 2602.
3. Overall depths of kerb bases will vary depending on carriageway construction.
4. Surface of kerb face to be cleaned before placing mortar or concrete backing.
5. Provide 25mm dia weep pipes at 5m centres on low channels laid on top of sub-base, where required in the task order.
6. Mortar to be Class1 to Clause 2404.
7. Taper kerbs to be used where kerb profile changes to standard high kerbs. This taper to be treated as full height high containment kerbs for measurement purposes.
8. For maintenance works the profile of high containment kerbs shall match existing.



Standard Detail
High Containment Kerb - Type 2

Version	Amendment	Date
Checked By: M.Batham	Drawing Number: SD-1100-05	Version: -
Date Issued: Oct 16		